



City of Three Rivers

333 West Michigan Avenue • Three Rivers, Michigan 49093

269.273.1075 • www.threeriversmi.org

Fax: 269.273.3132

TO: Bid Document Holders for Sewer Televising

FROM: City of Three Rivers – Amy Roth

RE: Addendum #1

DATE: February 15, 2016

The following are clarifications to the specifications of the above-mentioned project:

1. Water is available at 1015 S Lincoln Ave for the project. Our normal business hours are 7:00 am – 3:00 pm. We make special arrangements during weekdays for water before or after our normal first shift.
2. Root cutting for the this project is to be considered a part of the normal cleaning, and will NOT be classified as heavy cleaning
3. If pre-televising is not successful with access from the normal flow manhole, then you will be expected to go to the non-normal flow manhole and camera the opposite direction to get the most footage available.
4. With regards to the river crossing, this crossing is a concern for us as we are trying to trace any river water sources, so extensive bypass pumping may be necessary. We expect to get the clearest picture possible if there is water still under the river when televising and will be able to see if the water is coming into the line.

Thank you for your interest in this project. Any further questions may be directed to me at 269-273-1845 or aroth@threeriversmi.org.

Amy Roth, P.E.
DPS Director
City of Three Rivers